

Point Loma Nazarene University Fire report 2010

Fire Statistics:

Year	Number of Fires	Date	Building	Origin of Fire	Fatalities	Injuries	Bi-Annual Fire Drills	Property Damaged
2010	1	9/20/10	Nease 7-8	False - Burnt popcorn	0	0	2	\$ 0
2011	1	3/22/11	Nease 1-6	Malfunction Microwave	0	0	2	\$ 0
2011	1	9/23/11	Flex 43	Grease Fire	0	0	2	\$ 0

2010 Nease report, fire cause: report – microwave caused popcorn to burn. No actual fire, classified as false report by fire department.
 2011 Nease & Flex reports – Microwave was replaced and grease fire blackened hood and wall. There was not any damaged to either.

Fire Safety Systems:

Building	Sprinkler Type	Alarm Activation	Detection Sensor	Notification Local/Monitored	Annual Drills
Finch Hall	Sprinkler - monitored	Pull down - monitored	Smoke detector	Fire exit - local	2
Flex 41	Sprinkler local only	No	Smoke detector	N/A	2
Flex 42	Sprinkler local only	No	Smoke detector	N/A	2
Flex 43	No	No	Smoke detector	N/A	2
Flex 44	No	Pull down - local	Smoke detector	N/A	2
Flex 45	No	Pull down - local	Smoke detector	N/A	2
Flex 46	No	Pull down - local	Smoke detector	N/A	2
Flex 47	No	Pull down - local	Smoke detector	N/A	2
Flex 48	No	No	Smoke detector	N/A	2
Flex 49	No	Pull down - local	Smoke detector	N/A	2
Goodwin Hall	No	Pull down - local	Smoke detector	N/A	2
Hendricks Hall	No	Pull down - local	Smoke detector	Fire exit - local	2
Klassen Hall	No	Pull down - local	Smoke detector	Fire exit - local	2
Nease Hall 1-6	No	Pull down - local	Smoke detector	Fire exit - local	2
Nease Hall 7-8	Sprinkler - monitored	Pull down - monitored	Smoke detector	Fire exit - monitored	2

Wiley Hall	Sprinkler - monitored	Pull down - monitored	Smoke detector	Fire exit - local	2
Young Hall	Local pull down only	Stand pipe	Smoke detector	Fire exit - local	2

Policies for fire safety education and training programs for students, faculty & staff:

Fire in Residence Hall

- Pull all fire alarms while exiting building to evacuation area.
- Notify DPS of fire as soon as you are out of danger area.
 - DPS will notify emergency services and dispatch officers to assist with evacuation.
 - DPS will notify RD on duty.
 - **RD on duty will notify Dean of Students.**
 - DPS will send out mass text notifying students of the situation.
- Make sure that students are evacuated to an area that does not block emergency response vehicles.
- Organize students into RA groups and have RAs take record of which students are accounted for.
 - Do not allow students to leave evacuation area.
- Director of Public Safety, Dean of Students, or VP of Student Development will take control of situation once they are on scene.

*Please see PLNU Dorm policy on allowable appliance, portable electrical and safety.

* PLNU campus and any off-site work locations sponsored by PLNU are non smoking areas. Open flames such as candles are prohibited in dorms (see our student handbook policies: <http://www.pointloma.edu/experience/community/student-development/student-handbook/policies-regulations/student-conduct-policies/community-living/residential-life-policy>)

* For our Annual Security Report please follow this link: <http://www.pointloma.edu/experience/community/student-life/health-and-safety/public-safety/annual-safety-and-security-report>